



STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

PROCEDURE FOR SWIMMING POOL CLEAN-UP FECAL DISCHARGE - VOMIT DISCHARGE

- Close Pool
- Remove as much solid matter as possible using the skimming net-OSHA disposal
- Raise disinfectant level to 10 mg/l chlorine or equivalent
- Allow one complete filtration cycle (one turnover) of pool water volume to occur

Swimming Pools - 8 hrs or less if actual turnover rate known

Wading Pools - 2 hrs or less if actual turnover rate known

- Allow disinfectant level to adjust to 0.8 - 3.0 mg/l chlorine
- Re-open pool for use

n:\recrea\swimpool\Prcdrpol



Phone: (860) 509-7297

Telephone Device for the Deaf (860) 509-7191

410 Capitol Avenue - MS # 51REC

P.O. Box 340308 Hartford, CT 06134

An Equal Opportunity Employer