

Wallingford Fire Department

Office of the Fire Marshal

75 Masonic Avenue, Wallingford, CT 06492

Phone (203) 294-2766 Fax (203) 294-2736

firemarshal@wallingfordfd.com



EMERGENCY LIGHT TEST LOG

The Connecticut Fire Safety Code requires that all battery-powered emergency lights be tested monthly for 30 seconds and annually for 90 minutes. The Code also requires that written records of those tests be kept by the owner for inspection by the local Fire Marshal. Below an emergency lighting test log for your use.

Business Name/Address: _____ Year: _____

Emergency Light Location / #	January	February	March	April	May	June	July	August	September	October	November	December	Annual Test